

# DESIGN MATRIX

(Govt. Approved)

Project Management, Structural Design & Quantity Estimation

Ref. No. DM/2023/78

Date: 06/06/2023

## BUILDING SAFETY CERTIFICATE

I had visited **CARMEL CONVENT SCHOOL** Situated at- BLOCK D, SEC. 7, FARIDABD (Haryana) 121006.

Dated 06/06/2023.

The School building is 4<sup>th</sup> Storied Building.

The ground floor, first floor, second floor and third floor school Building is made on R.C.C. framed structured with R.C.C. columns, R.C.C beam & R.C.C. slab.

All outer & inner walls are 9" thick Brick masonry load Bearing Walls.

The school building as on today is structurally safe & sound as per the norms.

*Vipin*

VIPIN  
Structural Engineer  
Regd. No. ADMN-2017/14  
Mob: 9541010325

(Signature of Structural Engineer)